



Reg. No. 041/P-007

NOTIFIED BODY No. 1396
Osloboditeľov 282, 059 35 Batizovce, Slovakia
tel. +421 52 7752298 fax. +421 52 7881412 http://www.fires.sk



Certificate of constancy of performance

1396-CPR-0037

In compliance with Regulation (EU) No 305/2011 of the European Parliament and of the Council of 9 March 2011 (the Construction products Regulation or CPR), this certificate applies to the construction product

STATIC SMOKE BARRIER (SSB) MCR PROSMOKE ST CE

designed as a part of smoke and heat control systems, for creation of smoke reservoirs inside the building, for control of movement of smoke and heat inside the building and for increase of efficiency of natural or powered smoke and heat exhaust ventilators in accordance with EN 12101-1. Product properties are described in the Initial type-testing report No. C1396/09/0036/5004/SC (issued by FIRES, s.r.o., NB 1396 on 20. 01. 2010) amended by an actual report of continuous surveillance,

placed on the market under the name or trade mark of

“MERCOR” S.A.

ul. Grzegorza z Sanoka 2, 80-408 Gdańsk, Poland

and produced in the manufacturing plants

**“MERCOR” S.A., Zakład Produkcyjny Systemów Oddymiania i Wentylacji,
ul. Kwarцова 3A, Ciepłewo, 83 031 Łęgowo, Poland**

**“MERCOR” S.A., Zakład Produkcyjny Systemów Oddymiania i Wentylacji,
ul. Galaktyczna 32, 80-299 Gdańsk, Poland.**

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard

EN 12101-1: 2005, EN 12101-1:2005/A1: 2006

under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the

constancy of performance of the construction product.

This certificate was first issued on 20. 01. 2010 and will remain valid as long as neither the harmonized standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.

Batizovce, 26. 10. 2017

074084

FIRES 136a/C-31/01/2017-E



Ing. Mária Gašperová
Head of Product certification body